



འཕེལ་རྒྱུ་གཞི་གཙོ་སློབ་ལྷན་ཁག་ལྷན་འབྲེལ་ལུ་སྐོར་ལྷན་འབྲེལ་ལུ་
National Housing Development Corporation Limited
Thimphu : Bhutan



D&PS/CAU-12/2019/ 726

17th April 2019

ADDENDUM NUMBER 1

With reference to notice inviting tender for the “*Construction of 125 kVA sub Station and Extension of LV ABC cable for FCB Site A & B in Phuentsholing*” published in the Kuensel issue dated 13th April 2019, it is to inform all that following changes have been incorporated in the bidding document:

1. For SL.No.7.5 under SH-D, the description of the item is amended as “4 core, 150 sq.mm PVC insulated & Sheathed Aluminium Conductor cable, armoured 1.1 kV grade. (Havells/KEI/RR Kabel)”.
2. The following items to be added as Sl. no. 13 & 14 under SH-F as described below:
Sl. no.13 Digging of trench (0.8 m width & 1 m depth) for direct burial of UG cable.
Sl. no.14 Laying of UG cable.

Interested bidders are kindly advised to take note of the changes and accordingly **reflect the issue of this addendum in the form of bid.**

General Manager
D&PS, NHDCL

Copy to :

1. Chief Executive Officer, NHDCL for kind information
2. GM(s), NHDCL for information
3. Kuensel Corporation Ltd. with a request to publish the above Addendum in the forthcoming edition of 18th April, 2019
4. ICT Officer, NHDCL for information & necessary action

Head office: Post Box No.1439, Tel # (PABX: 00975-2- 323147/332734/332735)

Fax: 331703, 332733, 329095

Website: www.nhdcl.bt